OKLAHOMA DEPARTMENT OF TRANSPORTATION

FED. ROAD DIST. NO.	STATE	JOB PIECE NO.	FISCAL YEAR	SHEET NO.	TOTAL SHEETS
X	OKLA.	21899(04)			

REVISIONS

DESCRIPTION	DATE

SEC 33 T20N R14E

4-WP I-T

FO

SW

TMH

TMG

TMC

Asphalt

ABANDON EXISTING WATER LINE IN PLACE. CUT & PLUG END WITH CONCRETE.

N. 145TH E. AVE

TOP OF BANK

Treeline

Water Valve
Could not open

ODOT 145th E. AVE.
STA. 118+99.41, 28.56' RT

STA. 30+12.29 N=431669.58 E=2613320.20
FURNISHED BY CONTRACTOR, INSTALLED BY CONTRACTOR
1-8" 45° BEND, REST. 1-8" SOLID SLEEVE, REST.

30+12

30+00

29+00

28+00

SKELLY DR

Treeline

TOP OF BANK

ODOT 145th E. AVE.
STA. 117+95.46, 132.51' RT

STA. 28+65.19 N=431567.74 E=2613426.34
FURNISHED BY CONTRACTOR, INSTALLED BY CONTRACTOR
1-8" 45° BEND, REST. 1-8" GATE VALVE, REST. 1-VALVE BOX

PROPOSED 8" DIP WATER LINE

STA. 27+00

PRES.R/W

80'

ODOT 145th E. AVE.
STA. 116+93.92, 132.51' RT

STA. 27+43.65 N=431446.23 E=2613428.87
FURNISHED BY CONTRACTOR, INSTALLED BY CONTRACTOR
2-8" VERT. 45° BENDS, REST.

18" RCP SS

SSMH-15
152.79' Rt ℄ (A005)
Sta.119+99.74
TR=703.63'
℄(E)=693.08'
℄(S)=693.05'

SEC 34 T20N R14E

0 20 40 60
SCALE

WATERLINE SERVICE CONNECTIONS

WATERLINE STATION	OFFSET	RESET OR RECONNECT	SIZE
29+90	80' LEFT	RECONNECT	3/4"

SCALE:
HORIZ.: 1"=20'
VERT.: 1"=5'

715
710
705
700
695
690
685
680
675
670

GATE VALVE

EXISTING GRADE

PROPOSED 8" DIP WATER LINE

3' MIN.

+46

8" 45° VERT. BEND

+41

8" 45° VERT. BEND

8" 45° BEND

8" 45° BEND

+92

+12

RESTRAINED JOINTS

RESTRAINED JOINTS

+20

27+00
28+00
29+00
30+00
31+00

ATLAS PAGE NO. 296, 297, 369, 370

CITY OF TULSA ENGINEERING SERVICES DEPARTMENT	TMUA-W 14-01	ES 2014-02	SECTION MANAGER	ZTM	6/15	DESIGN	CML	12/14
			FIELD MANAGER	SDR	6/2015	DRAWN	MAM	12/14
			DEPUTY DIRECTOR	HMS	7/15	CHECKED	CML	4/15
			RECOMMENDED: W & S DIRECTOR	CE	8/15	APPROVED		
			APPROVED: CITY ENGINEER	TPR	8/15	SQUAD	GARVER	

TULSA & ROGERS COUNTIES

WATER LINE RELOCATION
(SHEET 4 OF 9)

STATE JOB NO. 21899(04) SHEET NO. W-7