

CLASS A CONCRETE:

ALL CONCRETE IN THE SLOPE WALL SHALL BE CLASS A CONCRETE AND SHALL BE POURED IN THE DRY. ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH SECTION 509 AND 610 OF THE STANDARD SPECIFICATIONS. COARSE AGGREGATE FOR THIN SECTION CONCRETE (701.06) MAY BE USED.

CONSTRUCTION JOINTS:

Ξġ

2:32:40

NO HORIZONTAL CONSTRUCTION JOINTS WILL BE PERMITTED IN THE SLOPE WALL. FINAL NUMBER AND LOCATION OF VERTICAL CONSTRUCTION JOINTS WILL BE DETERMINED BY THE ENGINEER. JOINTS WILL HAVE A MAXIMUM SPACING OF 10'-O" MEASURED ALONG THE TOE OF THE SLOPE WALL.

BASIS OF PAYMENT:

CONCRETE SLOPE WALL WILL BE MEASURED FROM EDGE TO EDGE AND FROM TOP TO BOTTOM OF THE TOP SURFACE OF THE SLOPE WALL AND FULL FACE OF THE TOE OF THE SLOPE WALL. PAYMENT WILL BE MADE AT THE CONTRACT PRICE BID FOR:

900.03 5" CONCRETE SLOPE WALL S.Y.

WHICH SHALL INCLUDE ALL COSTS OF JOINT SEALER AND FILLER, REINFORCING STEEL, CONCRETE, EXCAVATION, LABOR, FORMS, AND INCIDENTALS NECESSARY TO COMPLETE THE WORK AS SHOWN AND SPECIFIED.

FED. ROAD DIST. NO.	STATE	JOB PIECE NO.	F ISCAL YEAR	SHEET NO.	TOTAL SHEETS
6	OKLA.				
DESCRIPTI	DN	REVISIONS			DATE

PAY QUANTITY						
ITEM	DESCRIPTION	UNIT	QUANTITY			
510(C)	5" SLOPEWALL	S.Y.	246.3			

	DESIGN	-	-				
	DRAWN	-	-	LINE 3			
	CHECKED	-	-	SLOPEWALL "A" DETAILS			
	APPROVED	-	-	SLOFLWALL A DETAILS			
	SQUAD	P	DE	STATE JOB NO. <u>30444(06)</u> SHEET NO. <u>19</u>			
				OKLAHOMA COUNTY			